

# SAFETY PRECAUTIONS

## **CABINET RACKS**

**CR-273 CR-413** CR-413-6

- Follow this manual to obtain the optimum results before
- We also recommend you keep this manual handy for future reference.

#### Symbols

Symbol of caution actions



Symbol of prohibited actions





### 

Indicates a potentially hazardous situation which, if mishandled, could result in death or serious personal injury.

Avoid installing or mounting the unit in unstable locations, such as on a rickety table or a slanted surface. Doing so may result in the unit falling down and causing personal injury and/or property damage.



Prohibition

Install the unit only in a location that can structurally support the weight of the unit and the mounting bracket. Doing otherwise may result in the unit falling down and causing personal injury and/or property damage.



Caution



## 

Indicates a potentially hazardous situation which, if mishandled, could result in moderate or minor personal injury, and/or property damage.

Install the unit only in stable locations, and make appropriate arrangements to prevent it from falling down or rolling cross the floor. If it falls down or moves, this may cause personal injury and/or property damage.



Caution

When unpacking or moving a heavy unit, be sure to handle the unit with two or more persons, falling or dropping the unit may cause personal injury and/or property damage.



Caution

Be sure to put on gloves when assembling your equipment rack. Avoid barehanded work as this may cause injury by touching the cutting edges of rack components.



Caution

Do not place heavy objects on the unit as this may cause it to fall or break which may result in personal injury and/or property damage. In addition, the object itself may fall off and cause injury and/or damage.



Prohibition

Do not stand or sit on, nor hang down from the unit as this may cause it to fall down or drop, resulting in personal injury and/or property damage.



Prohibition